



## Office of the Municipal Council, Kinwat Dist Nanded

Phone No. (02469-222111) Fax No. (02469-222111) Email. cokinwat@gmail.com

out no. संकीर्ण / 2023

Date: 03/03/2023

To,

Principal,

Gyanjyoti Podar Learn School, Bendi

Tq. Kinwat Dist Nanded.

Subject: - Regarding obtaining fire brigade's no-disturbance certificate.

Reference: - Hon. Letter from Principal, Podar Learn School Kinwat

Data: 13/02/2023

In accordance with the above subject fire prevention and life protection measure scheme in your school building dt. On 13/02/2023 the site was visited by physical visit. Six extinguishers of 4Kg dry chemical powder and one extinguisher of Carbon Dioxide (Co2) were found for the first type of firefighting. Accordingly, the provisional no-obligation certificate is being issued subject to the following terms and conditions.

## **Terms and Conditions-**

- 1. It is necessary to ensure that the doors and stairs available for exit from the said school building can be opened immediately without any obstruction in case of emergency.
- 2. Emergency help information board in the said building (exit route, direction fire brigade, Police Station, Government Hospital and other important telephone no. etc.) Shall be written in detail in a prominent and prominent place.
- 3. Not to make any architectural changes or internal changes in the building. Nagar Palika obligatory to take NOC from will remain.
- 4. Storage of any kind of inflammable or inflammable material / articles shall be prohibited in the school premises.
- 5. The width of the gate should be such that the fire fighting vehicle can enter the compound of the building. Arrangements should be made to use the water tank on the roof of the building to be used for the amnesty system in case of emergency. The capacity of the water tank shall be 2000/5000 liters with a pump (fire pump) installed near the underground water storage tank and having a pressure of at least 0.3 N/MM2 at the terrace level.
- 6. There should be no wooden sheds in the premises of the school building which may cause fire The height of the partition of the building should be minimum. 7. Every 3 months of the monopoly supplying oxygen cylinders and diesel generators in your school as inspected by fire station supervisor or fire personnel. The height of the partition should be minimum.
- 7. Every 3 months of the monopoly supplying oxygen cylinders and diesel generators in your school as inspected by fire station supervisor or fire personnel. Servicing report should be near you.
- 8. Nameplates placed next to fire extinguishers should be fluorescent (glow at night). is necessary.
- 9. It is necessary to attach fire audit certificate of your school from authorized bodies appointed by Maharashtra Government Fire and Emergency Services.
- 10. If you do not follow the above instructions, you will be fully responsible for the accident.

11. Electrical inspection of school building should be done every 6 months by MSEB office.

- 12. The validity of the said non-validation certificate shall remain for 1 year from the date of issue.
- 13. Fire audit at the time of next renewal and electrical inspection every 6 months will be required to be attached with the application form from MSEB office.
- 14. Information and training should be given to your security guards / staff regarding fire system

Fire Assistant,
Fire Department,
Municipal Council,
Kinwat

## Verification

Mr. Bineesh K. S Age 44 Principal Gyanjyoti Podar learn School R/o Kinwat State an oath as under the contents of above said documents are translated from Marathi language & this contents are true and correct to the best of my knowledge & belief based on the record maintained by institute hence verified today at kinwat.

Principal.

Mr. Bineesh K

Gyajyoti Podar learn School

Kinwat, Dist Nanded.

1 8 MAR 2023'

SWORN BE FORE ME K.K.Sable(B.A.L.L.B.) Advocate & Notary Tg.Kinwat Dist.Nanded

Govt of (M.S.)

ONDRY



